

Town of Amherst Department of Public Works 2009 Water Quality Report

Dear Customer:

In the year 2009, your drinking water was supplied by the Town of Amherst (PWS ID#1008000). This annual report will detail where town water comes from, what it contains, and the risks water testing and treatment are designed to prevent. This is the 12th year this report has been disseminated. Although much of the information in this report is required, we will supplement those elements with information of interest to the public.


1. Water Sources


The Town currently has seven sources that contribute to meeting the water demand: Atkins Reservoir, the Pelham Reservoir System, the South Amherst Wells (#1 & #2), The Brown Well (#3), the Lawrence Swamp Well (#4) and the Bay Road Well (#5). Both surface water supplies, Atkins and Pelham, and Wells 1, 2 & 3 are used year round to satisfy the required demands. These five sources supply approximately 90% of the total water produced. Wells #4 and #5 operate during high demand periods and summer months when the reservoirs are low. In 2002, a Source Water Assessment Program (SWAP) was completed on the Amherst water system by the Massachusetts Department of Environmental Protection (MADEP). This SWAP report assesses the susceptibility of the Towns drinking water sources to contaminants and outlines recommendations for drinking water protection. A copy is available at the Department of Public Works and online at www.mass.gov/dep/water/drinking/swapreps.htm

2. Water Consumption Data

The average daily water consumption for the year 2009 was 3.042 million gallons, with a peak demand of 4.325 million gallons on April 29, 2009. In 2008 the residential per person water consumption rate was 57 gallons daily, well below the MADEP guideline of 80.

Daily Water Consumption in Million Gallons FY09





3. Substances Found in Tap Water

In order to ensure that tap water is safe to drink, MADEP and EPA promulgate regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and the Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water that must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at 800-426-4791, or online at www.epa.gov. Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

<u>Microbial Contaminants</u>- such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

<u>Inorganic Contaminants</u>- such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining and farming.

Pesticides and Herbicides- may come from many sources such as agriculture, urban storm water runoff, and residential uses.

<u>Organic Chemical Contaminants</u>- including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants- which can be naturally occurring or be the result of oil and gas production and mining activities.

4. Vulnerability Some people may be more vulnerable to contaminants in drinking water than the general population. Immune compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and some infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

5. Lead & Copper

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Amherst is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested by a private, state certified laboratory. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/index.html

Substance	MCLG	Highest Level	90% Value*	Action Level
Lead	0 mg/l	0.110 mg/l	0.011 mg/l	0.015 mg/l
Copper	1.3 m/l	0.160 mg/l	0.096 mg/l	1.3 mg/l

*The 90% Value is the value below which 90% of the data falls. If the 90% value is below the Action Level, no further action is necessary

6. Treatment Plant Efficiency

All water from surface water supplies is treated by coagulation of the insoluble contaminants and then filtered through a fine sand-like material. The effectiveness of this process is measured by the cloudiness of the water (turbidity) leaving the treatment plant. Turbidity occurs naturally as a result of soil erosion due to turbulence in the tributaries that supply the reservoir. The following turbidity data illustrates the daily average performance of the two water treatment plants that serve Amherst. Drinking water regulations require the turbidity to be less than 0.3 in 95% of the samples.

Samples are taken every 4 hours	Raw Wa	nter Turbidity	Treated Water	MCL		
Treatment Plant	Annual Maximum Average Reading		Annual Maximum Average Reading		95 % of Samples	
Centennial	0.55	0.90	0.07	0.11	<0.3	
Atkins	0.47	0.70	0.09	0.14	<0.3	

Note: All units measured in NTU = Nephelometric Turbidity Units

7. Water Quality

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. Sometimes the EPA or MADEP requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. All water sources are analyzed for the following chemical substances: inorganics (metals and salts), nitrate, nitrite, lead, copper, disinfection byproducts, volatile organic substances (petroleum and solvents) and synthetic organic compounds (herbicides and pesticides). The following table indicates contaminants that were detected in your drinking water. The definitions below will help explain the water quality table:

Important Drinking Water Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants (e.g. chlorine, chloramines, chlorine dioxide).

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

I. Regulated Substances	Date Tested	Unit	MCL	MCLG	Highest Detect Level	Range of Data	Major Sources	Violation
a) Inorganic Sub	stances							
Fluoride	10/06/2009	ppm	4	N/A	1.35	0.42 - 1.35	Added to prevent tooth decay	NO
Barium	6/8/2009	ppm	2	2	0.011	0.010 - 0.011	Erosion of natural deposits	NO
Nitrate (measured as nitrogen)	4/8/2009	ppm	10	10	1.9	ND - 1.9	Runoff from fertilizer; Leaching from septic tanks, Sewage; Erosion of natural deposits	NO
b) Disinfection (Contaminants						-	
Total Trihalomethanes	8 Sites, Quarterly	ppb	* 80		67.2	7.2 – 67.2	Byproduct from chlorination	NO
Haloacetic Acids	8 Sites, Quarterly	ppb	* 60		91.4	9.8 – 91.4	Byproduct from chlorination	NO
Combined Chlorine	Twice Monthly	ppm	4.0	0	3.5	ND - 3.5	Applied Disinfectant	NO
c) Radioactive C	Contaminants							
Gross Alpha (pCi/l)	9/24/2003	pCi/l	15	0	0.66	0.26 – 0.66	Erosion from natural deposits	NO
Radium 228 (pCi/l)	9/24/2003	pCi/l	5	0	0.75	0.21 – 0.75	Decay of natural and manmade deposits	NO
II.				MCLG	Highest			

			MCLG	Highest			
				Detected			
Date Tested	Unit	MCL		Level	Range of Data	Major Sources	Violation
						Road salt;	
6/08/2009	ppm	None	None	12	10.0 - 12.0	Chlorine; Lye	NO
						Natural deposits;	
4/10/2009	ppm	None	None	28	2.6 - 28	Landfills; Dumps;	NO
	6/08/2009	6/08/2009 ppm	6/08/2009 ppm None	6/08/2009 ppm None None	Date TestedUnitMCLDetected Level6/08/2009ppmNoneNone12	Date TestedUnitMCLDetected LevelRange of Data6/08/2009ppmNone1210.0 – 12.0	Date TestedUnitMCLDetected LevelRange of DataMajor Sources6/08/2009ppmNone1210.0 – 12.0Road salt; Chlorine; LyeNatural deposits;

^{*} Based on an annual running average

<u>Installing a new dishwasher?</u> Many dishwashers now have water hardness settings on them. The water in Amherst is considered soft (the range for soft being 0-60).



Old Gasoline: A common disposal problem that many homeowners have is the disposal of leftover gasoline and gasoline/oil mixtures that are used in various landscaping machinery. Gasoline loses its potency in about three months and should not be stored or left in machinery for extended periods of time. To properly dispose




of leftover gasoline or gasoline and oil mixtures, pour them into your vehicle's gas tank when the tank is nearly full. A good solution for off season storage of your machinery such as lawn mowers, weed whackers, snow blowers, etc. is to use a gasoline "conditioner" in the fuel. This additive is available at all hardware stores and will keep your gasoline/oil mixture fresh for up to one year and eliminate the problems associated with old gas in your machinery.

<u>Lawn Irrigation Systems</u> –

A water main break can cause reversal of flow in the water pipes, allowing hazardous materials to be sucked into the water system. A "Backflow Preventer" can keep this from occurring. Massachusetts State Law requires backflow prevention devices to be installed on all

irrigation systems and they must be tested annually. Irrigation systems are also prone to leakage and can result in high water bills, so turn the valve off when not in use. Refer to the Town website:

<u>amherstma.gov/government/departments/public works/water</u> to read "How to Read Your Water Meter".



http://www.mass.gov/dep/water/resources/fsusers.htm



For more information, call Robert Pariseau, Director of Water Resources, Amherst DPW at (413) 259-3115 Email: pariseaur@ amherstma.gov This report is also available on the web at www.amherstma.gov

Town of Amherst Department of Public Works 586 South Pleasant Street Amherst, MA 01002-2542

这份报告中有些重要的信息,讲到关于您所在 社区的水的品质。请您 找人翻译一下,或者请 能看得懂这份报告的朋 友给您解释一下。

El informe contiene información importante sobre la calidad del agua en su comunidad. Tradúzcalo o hable con alguien que lo entienda bien.

នេះជាសេចក្តីវាយការណ៏សំខាន់អំពីទីក ទទួលទាននៅទីក្រុងរបស់លោកអ្នក បើមិនយល់សូមមេត្តារកអ្នកបកប្រែថ្ អ្នកដែលយល់អំពីសេចក្តីវាយការណ៍ ពន្យល់ដល់លោកអ្នក។

Town of Amherst 2009
Drinking Water Quality Report